

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

EFFECTIVE FRIDAY JULY 24, 2009
DRINKING WATER PROBLEM CORRECTED
PlaVada Community Association Water System
It is no longer necessary to boil your tap water
or to consume bottled water.

As customers of the PlaVada Community Association (PV) Water System, you were notified on July 16, 2009, of the total coliform bacteria problem with the PV Water System and were advised to use boiled or bottled water for domestic purposes. PV is pleased to report that the problem has been corrected and that it is no longer necessary to use boiled or bottled water.

The problem was determined by PV staff to be the squirrels that had made their way into the 90,000 gallon water storage tank through the tank's vent screens. PV staff have repaired the tank's vent screens, have removed the squirrels from the tank, and have applied chlorination disinfection to the water storage tank. Furthermore, chlorine has also been injected into the distribution system at Well No. 3 and the distribution system has been thoroughly flushed.

Analytical results for samples taken from the PV water distribution system after the cleanup/disinfection process verify that the water system is now producing and distributing water that meets State of California drinking water quality standards for coliform bacteria. The State of California Department of Public Health, in conjunction with the PV Community Association, have determined that, based on water monitoring and water quality test results, the system water is potable and safe to drink. Consequently, the boil water notice of July 16, 2009, is hereby lifted and rescinded.

As always, you may contact PV at (530) 426-3980, or the State of California Department of Public Health at (530) 224-4800 with any comments or questions.

Please share this information with all the other people who may drink this water, especially those who may not have received this notice directly (for example, people in condominiums, apartments, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

PV apologizes for the inconvenience and thanks you for your patience. This notice is being sent to you by the PlaVada Community Association (State Water System ID No. 2910011).